

**EAST LAKE TARPON SPECIAL FIRE CONTROL DISTRICT**

**AIR FILTER REPLACEMENT SCHEDULE – ST 57**

	AH-1	OAH-2	AH-3	AH-4	AH-5	OAH-6	AH-7
JAN							
FEB							
MAR							
APR							
MAY							
JUN							
JUL							
AUG							
SEP							
OCT							
NOV							
DEC							

FILTER SIZES:		
AH-1	16 X 25 X1	TAKES 3
OAH-2	20 X 25 X 4	
AH-3	16 X 25 X 1	TAKES 3
AH-4	20 X 22 X 1	
AH-5	20 X 22 X 1	
OAH-6	20 X 25 X 4	
AH-7	20 X 20 X 1	

LOCATION	
AH-1	GENERAL QUARTERS
OAH-2	GENERAL QUARTERS
AH-3	GENERAL QUARTERS
AH-4	GENERAL QUARTERS
AH-5	COMMUNITY ROOM
OAH-6	COMMUNITY ROOM
AH-7	UPSTAIRS STORAGE

**Regular Air Handlers (AH) changed every 2 months**

**Outside Air Handlers (OAH) changed every 6 months**