


# East Lake Tarpon Special Fire Control District

	<b><i>SOP 930.2 1.5", 1.75", 3" Hose Service Testing</i></b>	
	<b>Implementation Date: 11/2000</b>	<b>Revision Date(s): 10/27/2009</b>
	<b>Reviewed Date(s):</b>	
<b>Forms or Attachments: None</b>		

## HOSE TESTING

**1.5", 1.75", 3" BY UNIT AND YEAR.**

**TESTING TO BE COMPLETED IN APRIL OF EACH YEAR**

2010	2011	2012	2013	2014	2015	STATION 56	STATION 57	STATION 58
A	B	C	A	B	C	529 1.75" & 3"		528 1.75" & 3"
B	C	A	B	C	A		525 1.75" & 3"	548 1.5", 1.75" & +3" FROM STORAGE
C	A	B	C	A	B	526 all 1.75" & 3"		549 1.5", 1.75", 3" ALSO FROM STORAGE 1.34"
2016	2017	2018	2019	2020	2021	STATION 56	STATION 57	STATION 58
A	B	C	A	B	C	529 1.75" & 3"	--	528 1.75" & 3"
B	C	A	B	C	A	--	525 1.75" & 3"	548 1.75" & 3"
C	A	B	C	A	B	526 1.75" & 3"	--	549 1.75" & 3"

Post at all stations

\*Hose test is to include all supply hoses and High Rise Kits. Total lengths of hose lines are not to exceed 300' each (See SOP 930 and test to NFPA Standard 1962 (2003) edition).