

East Lake Tarpon Special Fire Control District



SOP 930.1 5" Hose Service Testing

**Implementation
Date: 11/2000**

Revision Date(s): 11/05/2009

Reviewed Date(s):

Forms or Attachments: None

5" Hose testing to be completed in March of each year.

HOSE TESTING

2004	2005	2006	2007	2008	Station 56	Station 57	Station 58
C	B	A	C	B	529		
A	C	B	A	C			528
B	A	C	B	A	526	525	
2009	2010	2011	2012	2013	Station 56	Station 57	Station 58
C	B	A	C	B	529		
A	C	B	A	C			528
B	A	C	B	A	526	525	

Stations may come together to assist with test and reload hose always keeping two units available to respond to calls.

***Hose test is to include all supply connections. Total length of hose line are not to exceed 300 feet each. (See SOP 930 and test to NFPA 1962 standard (2003 edition.)**

POST AT ALL STATIONS