


East Lake Tarpon Special Fire Control District

	<i>SOP 921 Axes and Pike Poles</i>	
	Implementation Date: 11/2000	Revision Date(s): 09/2004
		Reviewed Date(s):
	Forms or Attachments: None	

Daily Checks

1. All axes and pike poles shall be checked daily for cracks, burns etc.
2. Tightness of axe heads and pike pole heads should be checked.
3. Cleanliness of tools shall be noted. Clean or paint if necessary.

Monthly Checks

1. The heads shall be cleaned and oiled, or painted if necessary.