

# East Lake Tarpon Special Fire Control District



## *SOP 937 Smoke Ejectors*

**Implementation  
Date: 11/2000**

**Revision Date(s): 01/2007**

**Reviewed Date(s):**

**Forms or Attachments: None**

### Daily Check

1. Check the cord and electrical connections. The grommet holding the cord must be intact. Replace if damaged or missing.
2. Check smoke ejector for proper operation.
3. Check oil and fuel levels.

### Weekly Check (every Monday)

1. If smoke ejector is dropped or falls refer to Vehicle Maintenance Officer for operating inspection.
2. Check door jam bar for proper operation.
3. Check oil and fuel levels.

### Monthly Checks

1. Clean and inspect for damage
2. Check oil and fuel levels.