


# East Lake Tarpon Special Fire Control District

	<b><i>SOP 935 Nozzles</i></b>	
	<b>Implementation Date: 11/2000</b>	<b>Revision Date(s): 09/2004</b>
		<b>Reviewed Date(s):</b>
	<b>Forms or Attachments: None</b>	

All nozzles shall be removed from pre-connects, master stream devices, compartments, and tail boards during monthly cleaning.

Nozzles shall be cleaned by immersing them in soapy water and operating all moving parts. They shall then be rinsed and dried. Proper operation of shut off and pattern adjustment shall be noted.

Note: To keep apparatus in service for fire fighting, do not remove all nozzles at the same time.

All nozzles not hooked to pre-connected systems shall remain in the open position to prevent dirt from collecting on the ball valve.